




Open Loop Heat Pump

Michael Bantle

SINTEF Energy Research



Superheated Steam Drying




Specific Energy Consumption:

- Dryer 0.8 kWh/kg
 - Ideal 0.63 kWh/kg
- Excess steam available
- Aim 0.2 kWh/h



SINTEF

Open Loop Heat Pump (Mechanical Vapor Recompression)



Why using Superheated Steam instead of Air as Drying medium?

Overall heat transfer coefficient c and viscosity η




$$H = m \cdot c \cdot \Delta T$$

$$RE = \frac{w \cdot d_p \cdot \rho}{\eta \cdot (1 - \epsilon)}$$

	T [°C]	STEAM	AIR
c [kJ/(kg K)]	100	2.042	1.012
	150	1.980	1.018
η [10 ⁻⁶ kg/ms]	100	12.27	21.94
	150	14.18	24.07

As higher c value
as higher drying rate

As lower η value
as better pore
diffusion










Refrigerant R718 (water)



- Abundance and Safety:
 - Most abundant elements on earth; low cost and nearly unlimited available
 - From environmental point of view: water is ideal refrigerant above 0°C
 - Non-toxicity, non flammable, 0 Ozone Depletion Potential, 0 Global Warming Potential
- Regulatory Relief:
 - Not subject to present or future environmental or safety regulations
- Efficiency:
 - High latent heat of evaporation (2270 kJ/kg); 4-5 times higher than hydrocarbons or CO₂
 - Critical temperature: 380-386°C
 - General high COP

Multistage systems

	COP	$COP_{(+Intercool)}$	$\dot{Q}_{ThermCap}$ [kW]	$\dot{Q}_{Intercool}$ [kW]	P_{Compr} [kW]	p_2 [bar]	T_2 [°C]
One Compressor 	12.79		247.3		19.3	2.03	187
Two Compressors 	6.57		255.4		38.9	3.67	270
Two Compr. + Intercooling 	6.12	6.46	240.6	12.8	39.3	4.13	213
Three Compressors 	4.50		263.7		58.6	6.12	351
Three Compr. + Intercooling 	4.00	4.38	237.3	22.6	59.3	7.84	255

Results of the Performance Analysis for Multi-Stage Compression for Compressor Speeds of $n = 82\,700$ rpm, Inlet Pressure $p = 1$ bar, Inlet Temperature $T = 105$ °C and Mass Flow of $\dot{m} \approx 0.1$ kg sec⁻¹, P_{Compr} is required compression power, p_2 the discharge pressure and T_2 the discharge temperature after the last compression stage

Cost for Compressor

MVR-Compressor	screw compressor		steam fans/blowers		Turbocompressor	
stages	1 stage		5 stage		2 stage	
Inlet	110°C/1bar		110°C/1bar		110°C/1bar	
Outlet	150°C/5bar		150°C/5bar		150°C/5bar	
Investment	1 200 000 €		700 000 €		50 000 €	
Capacity	1300 kW		1300 kW		1300 kW	
steam flow	2000 kg/h		2000 kg/h		2000 kg / h	
COP (W/W)	4.25		4.25		4.25	
net savings	8.48 GWh		8.48 GWh		8.48 GWh	
Location	Germany	Norway	Germany	Norway	Germany	Norway
net savings**	52 275 €	482 885 €	52 275 €	482 885 €	52 275 €	482 885 €
ROI	23 years	2.5 years	13.4 years	1.4 years	1 year	0.1 year
** based on: electricity 0.15€/kWh Germany, 0.07€/kWh Norway; gas 0.04€/kWh Germany 0.06 €/kWh Norway						



SINTEF

Technology for a
better society